

DRAWING NUMBER

PLAN HOLD CORPORATION • IRVINE, CALIFORNIA

REDUCED BY NUMBER 075AR

POSITION EDGE OF PRINT ON THIS LINE

DRAWING NUMBER

PLAN HOLD CORPORATION • IRVINE, CALIFORNIA

REDUCED BY NUMBER 075AR

POSITION EDGE OF PRINT ON THIS LINE

A-105  
CANTOR FITZGERALD  
D-01537 (3A/3) 6/25/86  
COMMUNICATIONS EQUIPMENT PLAN

591.365  
TAA 3550  
PC-356

REVISION		DESCRIPTION
ZONE	LTR	

EQUIPMENT DESCRIPTION AND QUANTITY

CABLE TYPE: 1 - 75 PAIR  
14 - 25 PAIR  
20 - 12 PAIR TEFLON

QUANTITY: 35

MANUFACTURER: AMERICAN CABLE

EQUIPMENT: INTERCONNECT PLANNING CORPORATION  
AND KEY EQUIPMENT CONSISTING OF  
CABINETS EACH 23" W x 19" D x 11"

ENVIRONMENTAL: 0°C - 40°C (32°F - 104°F)

WEIGHT: FULLY EQUIPPED - 350 POUNDS EACH

PRIMARY POWER: 111 - 129 VAC 57 - 63 HERTZ  
5.0A MAXIMUM DRAIN

HEAT LOAD: NORMAL HEAT DISPERSION - 85°F

STATION  
EQUIPMENT: IPC - EPBT - 10" H x 18" W x 3.5  
IPC - SER.II-6.50 H x 7.75 W x 4  
IPC - KE-36 -7.29 H x 12.40 W x

GENERAL NOTES

- ALL WORK SHALL BE PERFORMED IN ACCORDANCE WITH  
MENTS OF THE NEW YORK CITY BUILDING CODE, THE  
CODE, AND THE PORT AUTHORITY OF NEW YORK AND
- ALL CABLE SPECIFICATIONS SHALL BE APPROVED BY  
PRIOR TO PURCHASE AND INSTALLATION.
- ALL EQUIPMENT SHALL BE GROUNDED TO EARTH  
GROUNDING WIRE.
- THE MANUFACTURER COMPANY WILL PROVIDE  
IN ACCORDANCE WITH THE SPECIFICATIONS.
- MAIN DISTRIBUTION TRUNK SHALL BE 3/4" PLY  
TREATED PER NYC BUILDING CODE SECTION 26-5
- 12, 25, & 75 PR. WIRE TO BE SE - 12, 25 & 75  
CABLE WITH TEFLON JACKET.
- ALL CABLE SHALL BE TAGGED AS TO TENANT & SYS
- CABLE IN RAISED FLOOR AREA NOT IN CONDUIT, IS  
NOT A RETURN PLENUM. THIS RAISED FLOOR AREA  
SMOKE DETECTORS TO MEET FIRE REGULATIONS.

CONTRACT  
DATE APPRO



		UNLESS OTHERWISE SPECIFIED DIMENSIONS ARE IN INCHES TOLERANCES ON FRACTIONS DECIMALS ANGLES	H. D. 6/25/86			INTERCONNECT PLANNING CORPORATION		
			DRAWING STARTED DATE					
			DRAWN					
			CHECKED					
		MATERIAL:	ENGR		COMMUNICAT			
		FINISH:			SIZE CODE IDENT NO.	C 01537		
NEXT ASSY		USED ON						
APPLICATION					SCALE	H		